

REV750000			
	DESCRIPTION	DATE	APPROVED
1	CHG ALL DIMS TO MEAS. DIMS CHG DIMS TO MEAS. DIMS	10/80	BLR/AN
2	CHG FRONT TO REAR IN ZONE E11, ADDED FLAME DETECTOR IN NOTE B	11/80	BBG/AN
3	CHG DIMS 4'-3" TO 4'-0" ZONE H-10, CHG DIMS IN ZONES H-10, 9, 8, 11, 1, 2, 11, 1, 1 ADDED STL & OIL LTR. P-RING.	11/80	POJ JJJ
4	CHG DIMS IN ZONES C-11, D-11, 4-11 ADDED TUBING IN ZONE C-11 TABLE IN NOTE 3 PER CUST. COM. ADDED TUBING NOTE IN ZONE C-11	12/80	R/L
5	REPLACED 12-200 DIMS CHG FRONT TO SUP. REPLACED VERTICAL HENSE L-100T W/ 1/2" GAS DOWNWARD DIMS. ADDED VIEW "B".	12/80	BBG
6	CHG DIMS 9'-5" TO 9'-0" & 4'-1" TO 4'-0" IN ZONE H-2, ADDED CUTS IN ZONE H-2	6/81	R/L

FLAME DETECTOR		ASSIGNMENT
CUSTOMER	TAG NUMBER	FLAME DETECTOR
BURNER	X	X
07 G	X	X
08 G	"	"
09 G	"	"
10 G	"	"
11 G	"	"
12 G	"	"
208 C	"	"
209 C	"	"
210 C	"	"
211 C	"	"
212 C	"	"
307 H	"	"
308 H	"	"
309 H	"	"
310 H	"	"
311 H	"	"
312 H	"	"
407 D	"	"
408 D	"	"
409 D	"	"
410 D	"	"
411 D	"	"
412 D	"	"

NOTES:

1. FOR LIST OF REFERENCE DRAWINGS
SEE DWG NO.197002C.

2. EQUIPMENT FOR UNITS 1 THRU 4
IS IDENTICAL EXCEPT FOR
PLASMA ARC IGNITERS WHICH ARE
TO BE FURNISHED FOR THE LOWER
BURNER LEVEL OF UNIT 1 ONLY.
(BBW CONTRACT BR-614)

3. OWNER'S EQUIPMENT COMPONENT
IDENTIFICATION IS AS INDICATED (E.G.
A-1) IS TO BE PREFIXED AS
FOLLOWS WHERE "X" IS THE ASSOCIATED
UNIT NO. 1 THRU 4.

BURNER	XSGA-BN
FUEL OIL IGNITER	XSGE-IGN
PLASMA ARC IGNITER	XSGA-PT
FLAME DETECTOR	

4. FIRE ALARM UNIT ROW SIGNATURE
CORRESPONDS TO UNIT NUMBER.

BURNER XSGA-BNR-
FUEL OIL IGNITER XSGE-IGN-
PLASMA ARC IGNITER XSGA-PTL-
FLAME DETECTOR
FIRST DIGIT OF COL ROW DESIGNATION
RESPONDS TO UNIT NUMBER.

UNIT 1 UNIT 2 UNIT 3 UNIT 4

INTERMOUNTAIN POWER PROJECT
STEAM GENERATOR UNITS 1,2,3 & 4
PROJECT FILE 9255.62.3401
IPA CONTRACT 2010N

ARRANGEMENT
24 DUAL REGISTER
BURNERS
REAR WALL

294372 E

5-10013

334-0818-3
334-0818-3
334-0817-3

114-991-79	294372 E	6
------------	----------	---